


SEATTLE CITY LIGHT  
MATERIAL STANDARDS

No. 7226.6

Page 1 of 1

HINGE  
CONTINUOUS, UNDRILLED  
STAINLESS STEEL

DATE: Jan. 8, 1964  
Rev: May 3, 1973



STAINLESS STEEL, PLAIN, UNDRILLED, CONTINUOUS HINGE for general use, shall be of commercial "18-8" chromium-nickel alloy steel (300 series), with No. 2D finish on both sides.

Pin shall be fast, stainless steel.

Maximum length of joint (loop) shall be one inch.

Purchase Unit: 72-Inch Lengths

Stock Unit: Foot

Stock Number	Open Width In.	Metal Thickness Inc.	Pin Diameter In.
722658	1-1/16	.040 $\pm$ .005	.090
722660	2	.062 $\pm$ .005	.128

STANDARDS COMMITTEE CHAIRMAN	STANDARDS COORDINATOR	DIVISION HEAD	STEERING COMMITTEE CHAIRMAN
<i>A. McCabe</i>	<i>J. R. Carlson</i>	<i>J. R. Carlson</i>	<i>J. R. Carlson</i>